

2022 Consumer Confidence Report for Public Water System CEDARVIEW ESTATES

This is your water quality report for January 1 to December 31, 2022

For more information regarding this report contact:

CEDARVIEW ESTATES provides surface water from Cedar Creek Reservoir, located in Henderson County.

Name Joe Whatley

Phone 903-675-4316

Definitions and Abbreviations

| | |
|--|--|
| Definitions and Abbreviations | The following tables contain scientific terms and measures, some of which may require explanation. |
| Action Level: | The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. |
| Avg: | Regulatory compliance with some MCLs are based on running annual average of monthly samples. |
| Level 1 Assessment: | A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system. |
| Level 2 Assessment: | A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions. |
| Maximum Contaminant Level or MCL: | The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. |
| Maximum Contaminant Level Goal or MCLG: | The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. |
| Maximum residual disinfectant level or MRDL: | The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. |
| Maximum residual disinfectant level goal or MRDLG: | The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| MFL | million fibers per liter (a measure of asbestos) |
| mrem: | millirems per year (a measure of radiation absorbed by the body) |
| na: | not applicable. |
| NTU | nephelometric turbidity units (a measure of turbidity) |
| pCi/L | picocuries per liter (a measure of radioactivity) |
| ppb: | micrograms per liter or parts per billion |
| ppm: | milligrams per liter or parts per million |
| ppq | parts per quadrillion, or picograms per liter (pg/L) |
| ppt | parts per trillion, or nanograms per liter (ng/L) |
| Treatment Technique or TT: | A required process intended to reduce the level of a contaminant in drinking water. |

Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Information about Source Water

CEDARVIEW ESTATES purchases water from CAROLYNN ESTATES. CAROLYNN ESTATES provides purchase surface water from Cedar Creek Reservoir, located in Henderson County.

| Contaminant | Year | Average Level | Minimum Level | Maximum Level | MCL | MCLG | Units | Source of Constituent |
|----------------------|------|---------------|---------------|---------------|------------------|------------------|-------|--|
| Barium | 2022 | 0.057 | .057 | .057 | 2 | 2 | ppm | Discharge of drilling wastes;discharge of metal refineries;erosion of natural deposits. |
| Cyanide | 2022 | 76.7 | 76.7 | 76.7 | 200 | 200 | ppb | Discharge from steel/metal factories; discharge from plastic and fertilizer factories |
| Fluoride | 2022 | 0.071 | 0.071 | 0.071 | 4 | 4 | ppm | Erosion of natural deposits.water additive which promotes strong teeth; discharde from fertilizer and aluminum factoriws |
| Nitrate | 2022 | 0.036 | 0.036 | 0.036 | 10 | 10 | ppm | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |
| Dibromochloromethane | 2022 | 3.63 | 3.63 | 3.63 | None Established | None Established | ppb | Byproduct of drinking water disinfection |
| Chloroform | 2022 | 22.9 | 22.29 | 22.9 | None Established | None Established | ppb | Byproduct of drinking water disinfection |
| Bromodichloromethane | 2022 | 13.1 | 13.1 | 13.1 | None Established | None Established | ppb | |

| Contaminant | Year | Average Level | Minimum Level | Maximum Level | Limit | Units | Source of Constituent |
|-------------|------|---------------|---------------|---------------|-------|-------|--|
| Aluminum | 2022 | .014 | .014 | .014 | .2 | ppm | Naturally occurring element |
| Calcium | 2022 | 19.1 | 19.1 | 19.1 | NA | ppm | Naturally occurring element |
| Chloride | 2022 | 23.9 | 23.9 | 23.9 | 300 | ppm | Naturally occurring element;used in water purification; byproduct of oilfield activity |
| Sodium | 2022 | 22.0 | 22.0 | 22.0 | NA | ppm | Naturally occurring element |
| Sulfate | 2022 | 57.9 | 57.9 | 57.9 | 300 | ppm | Naturally occurring element; byproduct of oilfield activity |
| Magnesium | 2022 | 3.76 | 3.76 | 3.76 | NA | ppm | Naturally occurring element |
| Contaminant | Year | Average Level | Minimum Level | Maximum Level | Limit | Units | Source of Constituent |

| | | | | | | | |
|---------------------------|------|-------|-------|-------|------|-------|---|
| Manganese | 2021 | 0.005 | 0.005 | 0.005 | 0.05 | ppm | Naturally occurring element |
| Hardness | 2021 | 61.4 | 61.4 | 61.4 | NA | ppm | Naturally occurring calcium and magnesium |
| Zinc | 2022 | .006 | .006 | .006 | 5 | ppm | Moderately abundant naturally occurring element; used in the metal industry |
| Total Alkalinity as CaCO3 | 2022 | 36 | 36 | 36 | NA | ppm | Naturally occurring soluble mineral salts |
| Total Hardness as CaCO3 | 2022 | 63.1 | 63.1 | 63.1 | NA | Ppm | Naturally occurring calcium |
| Combined Radium226 &228 | 2021 | 1.5 | 1.5 | 1.5 | 5 | pCi/L | Erosion of natural deposits |

| Contaminant | Year | Average Level | Minimum Level | Maximum Level | MCL | MCLG | Units | Source of Constituent |
|------------------------|------|---------------|--|---------------|------|-------|---|--|
| Atrazine | 2021 | .01 | .01 | .01 | 3 | 3 | ppb | Runoff from herbicide used on row crops. Discharge from rubber and chemical factories. |
| Contaminant | Year | High | Lowest Monthly % of Samples Meeting Limits | MCL | MCLG | Units | Source of Constituent | |
| Turbidity | 2022 | 0.8 | 100% | 0.3 | NA | NTU | Soil run off | |
| Total Dissolved Solids | 2022 | 168 | 168 | 168 | 100 | Ppm | Total dissolved mineral constituents in water | |

TCEQ completed a Source Water Susceptibility for all drinking water systems that own their sources. This report describes the susceptibility and types of constituents that may come into contact with the drinking water source based on human activities and natural conditions. The system(s) from which we purchase our water received the assessment report. For more information on source water assessments and protection efforts at our system contact Lakeshore Utility at 903-675-4316

| Lead and Copper | Date Sampled | MCLG | Action Level (AL) | 90th Percentile | # Sites Over AL | Units | Violation | Likely Source of Contamination |
|-----------------|--------------|------|-------------------|-----------------|-----------------|-------|-----------|--|
| Copper | 12/28/2020 | 1.3 | 1.3 | 0.021 | 0 | ppm | N | Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems |
| Lead | 12/28/2020 | 0 | 15 | 1.6 | 0 | ppb | N | Corrosion of household plumbing systems; Erosion of natural deposits. |

2022 Water Quality Test Results

| Disinfection By-Products | Collection Date | Highest Level Detected | Range of Individual Samples | MCLG | MCL | Units | Violation | Likely Source of Contamination |
|--------------------------|-----------------|------------------------|-----------------------------|------|-----|-------|-----------|--------------------------------|
|--------------------------|-----------------|------------------------|-----------------------------|------|-----|-------|-----------|--------------------------------|

| | | | | | | | | |
|--------------------------------|------|----|----------|-----------------------|----|-----|---|--|
| Haloacetic Acids (HAA5) | 2022 | 42 | 9.8 - 40 | No goal for the total | 60 | ppb | N | By-product of drinking water disinfection. |
|--------------------------------|------|----|----------|-----------------------|----|-----|---|--|

*The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year

| | | | | | | | | |
|-------------------------------------|------|----|-----------|-----------------------|----|-----|---|--|
| Total Trihalomethanes (TTHM) | 2022 | 66 | 26.2 - 63 | No goal for the total | 80 | ppb | N | By-product of drinking water disinfection. |
|-------------------------------------|------|----|-----------|-----------------------|----|-----|---|--|

*The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year

| Inorganic Contaminants | Collection Date | Highest Level Detected | Range of Individual Samples | MCLG | MCL | Units | Violation | Likely Source of Contamination |
|---------------------------------------|------------------------|-------------------------------|------------------------------------|-------------|------------|--------------|------------------|--|
| Nitrate [measured as Nitrogen] | 2022 | 0.252 | 0.252 - 0.252 | 10 | 10 | ppm | N | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |

Disinfectant Residual

| Disinfectant Residual | Year | Average Level | Range of Levels Detected | MRDL | MRDLG | Unit of Measure | Violation (Y/N) | Source in Drinking Water |
|------------------------------|-------------|----------------------|---------------------------------|-------------|--------------|------------------------|------------------------|--|
| Chloramines | 2022 | 2.1 | 1.9-2.2 | 4 | 4 | ppm | N | Water additive used to control microbes. |